

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Decatur 61	COUNTY Macon
FACILITY NAME Dennis Lab Kaleidoscope (Formerly French Academy)	FACILITY LOCATION 520 W. Wood Street, Decatur

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 01/04/2023 by Chad Ramey.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
-----------------	---	------------------------

4	Administration and General	Room #8 is s a self closing door to classroom and still has old floor door stop in place. Door stop needs to be removed for proper fire rating.
---	----------------------------	---

District's Response

Kent Metzger 02/22/2023 The door stop will be removed.Â Â

6	Administration and General	Exit signs in most areas were hard wired but are not battery back up. Battery back up lights need to be installed. Maintenance employee advised some emergency lighting in some areas need to be upgraded and will possibly install dual purpose lighting and exit signs. Need exit sign installed rear exit of Kitchen labeled door "E".
---	----------------------------	---

District's Response

Kent Metzger 02/22/2023 Corrections will be made as noted.Â Â

25	Administration and General	Room 3 needs second GFI installed in area of sink. Maintenance staff advised and will be making repair and notify when completed.
----	----------------------------	---

District's Response

Kent Metzger 02/22/2023 The GFI will be installed as noted.Â Â

122	Elevator and Conveying Systems	Staff advised elevator has been inspected but waiting on certificate. Maintenance staff will notify me and advise when received and posted.
-----	--------------------------------	---

District's Response

Kent Metzger 02/22/2023 Bldgs. & Grounds staff have made further inquiry with the OSFM about why we have yet to receive the needed documentation.Â Â

285	Storage/Supply/Closets	3rd floor janitor closet door does not fully close or latch so closet can be locked. Door needs repaired or replaced
-----	------------------------	--

District's Response

Kent Metzger 02/22/2023 Door will repaired as noted.Â Â